



DC Water Total Coliform Monthly Report – December 2013

Sample	Number of Samples
Number of total coliform samples collected	243
Positive (percent)	0%
Number of routine total coliform samples collected ¹	243
(a) Number of instances where residual disinfectant measured	243
(b) Number of instances where no chlorine measured and HPC measured	0
(c) Number of instances where residual disinfectant measured but not detected and no HPC is measured	0
(d) Number of instances where no residual disinfectant detected and HPC is <500	0
(e) Number of instances where no residual disinfectant is measured and HPC is >500	0
V (current month) % indicating no residual disinfectant [(c+d+e)/(a+b)x100]	0%
(V) from previous month	0.4%

¹ Number of routine monitoring samples do not include repeat samples. All calculations in the table are based on all samples collected.

			Sample collection period	
			02-Dec- 13	23-Dec-13
Param	# of Samples	Average	Maximum	Minimum
Free Cl ₂	243	0.05	0.46	ND
pH	243	7.65	7.92	7.24
Temperature	243	11.87	20.00	7.10
Total Cl ₂	243	3.36	4.10	0.18